



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049  
Columbus, OH 43216-1049

August 24, 2010

Brent Winland  
Northmor Local School District  
5247 County Road 29  
Galion, OH 44833

**Re: Construction Storm Water Inspection at Northmor K-12 School / Morrow County  
Permit Number 4GCO00002\*AG**

Dear Mr. Winland:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley and Megan Reising of Ohio EPA at 5247 County Road 29 Galion, Ohio on August 05, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. The following was noted:

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Please ensure good management practices throughout the construction phase of this project, as maintenance of the sediment and erosion controls remain an issue at this site.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Northmor K-12 School 8-5-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director