



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3888
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

October 18, 2010

D Steven Allen
London City School Dist
60 S Walnut Street
London, OH 43140

Re: **Construction Storm Water Inspection at London Middle School
Madison County
Permit Number: 4GC03193*AG**

Dear Mr. Allen:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley of Ohio EPA at London Middle School located on Future Keny Boulevard across 336 Elm Street and 380 Elm Street London, Ohio, on October 4, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- During the inspection, it was noted that all previous concerns with regards to the retention pond and discharge storage have been adequately addressed. Please continue to inspect and maintain sediment controls every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches to ensure continued effectiveness of the sediment basin.
- Please be aware measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm London Middle School 10-4-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

