



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

September 8, 2010

Mike Bashore  
Franklin County Engineer's Office  
970 Dublin Road  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Clime Road / Franklin County  
Permit Number: 4GC03214\*AG**

Dear Mr. Bashore:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Stephen Riley of the Ohio EPA at Clime Road from Georgesville Road to Demorest Road in Columbus, Ohio on September 7, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The northern and southern silt fences, on both sides of Clime Road near Georgesville Road, have become overrun with soil from the adjacent slope and require maintenance at this time.
- The areas of disturbed areas near the stream crossing do not appear to be adequately protected from erosion. Please install protections along the barren areas on the banks of the stream.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Clime road (From Georgesville to Demorest Road) 9-7-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director