



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Roger Loomis  
City of Newark Ohio  
34 South 5<sup>th</sup> Street  
Newark, OH 43055

**Re: Construction Storm Water Inspection at Newark WWTP/ Licking County.  
Permit Number 4GC03069\*AG**

Dear Mr. Loomis:

This letter is written in follow-up to a construction storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at **Newark WWTP** located 1003 East Main Street in Newark, Ohio on August 23, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The silt fence along the crop fields was damaged and will require maintenance at this time. Corrective measures are expected within three days from receipt of this letter.
- Inlet protections located on site are not covered appropriately to minimize sediment runoff into the storm sewer systems. The inlet protections must be covered with Dandy bags or equivalent.

**Maintenance:**

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Roger Loomis  
City of Newark Ohio  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Newark WWTP 8-23-2010