



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 9, 2010

Jim Ohlin
Ryan Homes
921 Eastwind Drive Suite 118
Westerville, OH 43081

**Re: Construction Storm Water Inspection at Taylor Glen Section 4 (Lots 214-225)
Licking County
Permit Number: 4GC03334 *AG**

Dear Mr. Ohlin:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Stephen Riley of the Ohio EPA at Taylor Glen Section 4 (Lots 214-225) located at the intersection of Havens Corner Road and Taylor Road on August 16, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The installed straw wattles along Haven Corners Road are not adequate for sediment control. The control is currently failing and not installed properly. Alternate measures are expected.
- At the time of inspection, sediment laden water from the site was flowing into a street-side catch basin on the northwest corner of the project. This catch basin did not appear to have means of inlet protection. Please correct this situation to minimize off-site sediment transport to waters of the state.
- The area along Havens Corner Road appeared to have been seeded, but it appears that the seeding has not reached the required minimum density of 70% vegetative cover. Please continue to evaluate this area for improvement.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

Ted Strickland, Governor

Lee Fisher, Lieutenant Governor

Chris Korleski, Director

HK/nsm Taylor Glen Section 4 (Lots 214-225) 8-16-2010