



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3776 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 9, 2010

Ed Den- Haan
Ralph Fallon Builders Inc.
5755 Zarley Street
New Albany OH 43054

**Re: Construction Storm Water Inspection at Medors Residence/ Licking County.
Permit Number 4GC03233*AG**

Dear Mr. Den-Haan,

This letter is written in follow-up to a construction storm water inspection conducted by Vinod Tujalpuram and Abigail Tamkin of Ohio EPA at **Medors Residence** located at 5920 Dutch Lane Road in Johnstown, Ohio on August 23, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The silt fence located along the western end of the project must be entrenched to ensure a proper functioning condition. Corrective measures are expected within three days from receipt of this letter.
- During the inspection our staff observed sediment laden water from the dewatering activities is diverted into the adjacent stream located on the western end of the project. Please ensure future dewatering activities do not result in turbid disturbances to waters of the state.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on-site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ed Den- Haan
Ralph Fallon Builders Inc.
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DWS/CDO

HK/nsm Medors Residence 8-23-2010