



State of Ohio Environmental Protection Agency

Central District Office

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 27, 2009

Bob Hesotian
Champion Environmental Services
38 West End Drive
Gilberts, IL 60136

**Re: Storm Water Inspection at Columbus Coated Fabrics / Franklin County
Permit #: 4GC02432*AG**

Dear Mr. Hesotian:

This letter is written in follow-up to a construction storm water inspection by Amber Miller, of the Ohio EPA, conducted at Columbus Coated Fabrics located at 1280 North Gran on (date). The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Upon inspection, it appeared the perimeter silt fence was functioning as intended.
- The two sediment traps were noted on site. I understand you are currently working with the city of Columbus to improve the intended function of the sediment traps which the agency supports.
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- During the inspection our staff noted the seeding efforts. Please continue seeding efforts to ensure the area is stabilized until further construction activities take place. This especially pertains to the large dirt pile indicated in Figure 1.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Bob Hesotian
Champion Environmental Services
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Columbus Coated Fabrics 7-15-09