



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 23, 2009

Steve Geiger  
Reclamation, LLC  
65 Southwind Drive  
Gahanna, OH 43230

**Re: Storm Water Inspection at Bedford II**

Dear Mr. Geiger:

46C03047-A-G

This letter is written regarding the storm water inspection I conducted at Bedford II, located in Gahanna, Ohio on July 14, 2009. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted:

**Sediment and Erosion Controls**

- The diversions that transport storm water runoff from the site have been completed. Based on my site observations, all storm water from affected areas are now routed to the impoundment intended for sediment control.
- Please finalize the outlet structure to the sediment pond in accordance with your approved plan. Please ensure the plan is closely followed in order to acquire the sediment storage volumes mandated in the General Permit. Please contact me upon completion of the outlet structure so I may evaluate the sediment pond to ensure appropriate construction.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Steve Geiger  
Reclamation, LLC  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Bedford II July 14, 2009