



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 23, 2009

Steve Fulkert
Murphy Development Company
4393 Arbor Lake Drive
Groveport, OH 43125

**Re: Storm Water Inspection at Asherton Grove of West Albany / Franklin County
Permit #: 4GC02356*AG**

Dear Mr. Fulkert:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Katie Anderson, of the Ohio EPA, at Asherton Grove of West Albany located at 4601 Central College Road on July 16, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls

- Upon inspection, it appeared there is no active construction on this site. Please be aware that all sediment and erosion controls must be maintained until such time vegetation is fully established sufficient to control erosion.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Asherton Grove of West Albany 7-16-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director