



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

Scott W. Maruniak
North Union Local School District
12920 State Route 739
Richwood, Oh 43344

**Re: Storm Water Inspection at North Union Middle School
Permit #4GC02674*AG**

Dear Mr. Maruniak:

This letter is written in follow up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at North Union Middle School located at Grove Street and Mulvane Road in Union County on July 6, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- It was apparent that the school is near completion. Please ensure all vegetation is established sufficiently to control erosion. All sediment controls must be maintained until vegetation is established at a 70 percent density.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements are found at: <http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html>.


Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Scott W. Maruniak
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO