



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 10, 2010

Aldino Stazzone
OSU- Facilities Design & Construction
400 Central Classroom Bldg
2009 Millikin Road
Columbus, OH 43210

**Re: Construction Storm Water Inspection at OSU Medical Center Improvements
(Medium Voltage Part 1) and OSU Medical Center Improvements
Franklin County
Permit Number: 4GC03171*AG & 4GC03058*AG**

Dear Mr. Stazzone:

This letter is written regarding the storm water inspection, I conducted at OSU Medical Center Improvement (Medium Voltage Part 1) and OSU Medical Center Improvements located at 1654 Upham Drive in Columbus Ohio on August 26, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- The storm drain located in front of the Medical Center Building on W 10th Avenue has been damaged and will require maintenance at this time. Corrective measures are expected within three days from receipt of this letter.
- There is evidence that the water from dewatering activities was discharged into the storm drains located on site at the intersection of West 12th Avenue and Cannon Drive (See Photos). Please ensure the dewatering from the impoundments do not result in turbid disturbances to the waters of the state.

Maintenance


- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Aldino Stazzone
OSU- Facilities Design & Construction
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm OSU Medical Center Improvements, 8-26-2010



Figure 1: Sediments seen running off into the storm drain.




Figure 2: Storm drain left opened.