



State of Ohio Environmental Protection Agency

REET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

September 9, 2010

Mitch Vincent  
Corna Kokosing  
6235 Westerville Road  
Westerville, OH 43081

**Re: Construction Storm Water Inspection at Motorist Mutual Insurance Company  
Data Center / Franklin County  
Permit Number: 4GC03095\*AG**

Dear Mr. Vincent:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Stephen Riley of the Ohio EPA at Motorists Mutual Insurance Company Data Center located at 6650 New Albany Road East, New Albany, Ohio on August 18, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**


- During the site investigation, it was found that the dewatering activities noted on site resulted in turbid discharges to waters of the state (see photo). Be aware this is a direct violation of ORC 6111.04 and your storm water permit. Measures must be implemented immediately to ensure there are no further turbid discharges resulting from your dewatering activities.
- Our staff observed a barren area at the corner of New Albany Road and the entrance to the site (Figure 2). Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Mitch Vincent  
Corna Kokosing  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Motorists Mutual Insurance 8-18-2010



Motorists Mutual Insurance Co Data Center  
Rocky Fork Creek  
Photo by: Stephen Riley and Abigail Tamkin  
August 18, 2010

**Figure 2: Dewatering from sanitary sewer to unprotected storm water**



Motorists Mutual Insurance Co Data Center  
Rocky Fork Creek  
Photo by: Stephen Riley and Abigail Tamkin  
August 18, 2010

**Figure 1: Barren area at entrance to site**