



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 23, 2009

Bob Hoying  
555 Metro Place North  
Dublin, OH 43017

**Re: Storm Water Inspection at New Residential Residence/Permit #4GC02482\*AG**

Dear Mr. Hoying:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at the residence located at 9233 Hyland Croy Road in Union County on July 7, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- The area around the house and near the pond must be stabilized to ensure appropriate protection from erosion (See Photo Figure 1). Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Residence July 7, 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director




Figure 1: Area near house requiring protection from erosion