



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



October 9, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Paul L. Wilkins  
Apollo Mobile Home Park  
9524 West Bloom Road  
Oak Harbor, Ohio 43449

Sandusky County  
Apollo Mobile Home Park  
Community PWS  
PWS ID: OH7200012

Dear Mr. Wilkins:

The Public Water System serving Apollo Mobile Home Park is in violation of the Ohio Administrative Code (OAC) for failure to comply with the operational requirements of OAC 3745-83-01 during the month of August, 2012.

In violation of OAC 3745-83-01(F)(5)(a)(ii), the public water system failed to report iron at the plant tap: There were 3 week(s) during the month in which no analysis was reported.

In violation of OAC 3745-83-01(F)(5)(a), the public water system failed to report the monthly iron quality control lab split sample.

If you have any questions, please contact me at (419) 373-3108 or via e-mail at [Janis.Damico@epa.state.oh.us](mailto:Janis.Damico@epa.state.oh.us).

Sincerely,

Janis D'Amico  
Division of Drinking and Ground Waters

/lir

pc: Sandusky County Health Department  
DDAGW – NWDO

ec: Linda Benham, DDAGW-NWDO

18-10-2020