



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 27, 2007

RE: HOLMES COUNTY  
CLARK TOWNSHIP  
CHARM GENERAL STORE  
4456 SR 557  
NPDES #3PR00415

Mr. Ed Raber  
Charm Corporation, Inc.  
P.O. Box 25  
Charm, OH 44617

Dear Mr. Raber:

On September 25, 2007, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

The treatment system consists of a 500-gallon-per-day Orenco Systems AdvanTex recirculating textile filter. The system was installed in August of 2007. At the time of the inspection, the treatment plant was not discharging.

A review of your self-monitoring reports covering the period March 2007 through August 2007 revealed the following effluent violations:


Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2007	001	Dissolved Oxygen	1D Conc	6.0	3.99	3/15/2007
May 2007	001	Dissolved Oxygen	1D Conc	6.0	5.73	5/4/2007
May 2007	001	Dissolved Oxygen	1D Conc	6.0	2.	5/9/2007
May 2007	001	Dissolved Oxygen	1D Conc	6.0	5.	5/17/2007
May 2007	001	Dissolved Oxygen	1D Conc	6.0	3.64	5/22/2007
June 2007	001	Dissolved Oxygen	1D Conc	6.0	.19	6/4/2007
June 2007	001	Dissolved Oxygen	1D Conc	6.0	1.21	6/11/2007
June 2007	001	Dissolved Oxygen	1D Conc	6.0	.7	6/15/2007
June 2007	001	Dissolved Oxygen	1D Conc	6.0	.09	6/22/2007
July 2007	001	Dissolved Oxygen	1D Conc	6.0	.53	7/3/2007
July 2007	001	Dissolved Oxygen	1D Conc	6.0	.04	7/9/2007
July 2007	001	Dissolved Oxygen	1D Conc	6.0	.04	7/16/2007
July 2007	001	Dissolved Oxygen	1D Conc	6.0	1.28	7/24/2007
August 2007	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	40.	8/1/2007
August 2007	001	Nitrogen, Ammonia (NH3)	30D Qty	0.0019	.09084	8/1/2007
August 2007	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	40.	8/8/2007
August 2007	001	Nitrogen, Ammonia (NH3)	7D Qty	0.0028	.09084	8/8/2007
August 2007	001	Dissolved Oxygen	1D Conc	6.0	1.13	8/9/2007
August 2007	001	pH	1D Conc	6.5	1.55	8/17/2007
August 2007	001	pH	1D Conc	6.5	5.09	8/22/2007

Mr. Ed Raber  
Charm Corporation, Inc.  
September 27, 2007  
Page 2

It was noted that the flow meter that was shown on the detail plans of PTI #02-21233 was not installed.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Kraig Bucklew Holmes County Health Department  
Kevin Dean

File: Semi-Public/Charm General Store