



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 10, 2008

RE: HOLMES COUNTY  
BERLIN TOWNSHIP  
WISE ELEMENTARY  
4579 CR 120  
NPDES 3PT00119

Mr. Junior Troyer  
East Holmes Schools  
P.O. Box 182  
Berlin, OH 44610

Dear Mr. Troyer:

On September 9, 2008, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the sewage treatment system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a good color and the clarifier effluent was clear. The surface sand filters were in good condition and the contents of the chlorine contact tank were clear.


A review of monthly operating reports covering the period September 2007 through August 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2007	001	Dissolved Oxygen	1D Conc	6.0	5.23	9/17/2007
October 2007	001	Dissolved Oxygen	1D Conc	6.0	5.55	10/15/2007
March 2008	001	pH	1D Conc	9.0	9.62	3/17/2008
May 2008	001	Dissolved Oxygen	1D Conc	6.0	5.78	5/9/2008
May 2008	001	Dissolved Oxygen	1D Conc	6.0	5.95	5/16/2008
May 2008	001	Dissolved Oxygen	1D Conc	6.0	5.8	5/23/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	5.78	6/9/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	5.95	6/16/2008
June 2008	001	Dissolved Oxygen	1D Conc	6.0	5.8	6/23/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	5.81	7/1/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	5.6	7/9/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	5.7	7/15/2008
August 2008	001	Dissolved Oxygen	1D Conc	6.0	5.81	8/8/2008
August 2008	001	pH	1D Conc	9.0	18.5	8/15/2008

MR. JUNIOR TROYER  
WISE ELEMENTARY  
SEPTEMBER 10, 2008  
PAGE 2

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mlh

cc: Holmes County Health Department, Attn: Kraig Bucklew  
Kevin Dean

File: Semi-Public/Wise Elementary