



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 21, 2007

RE: HOLMES COUNTY  
WASHINGTON TOWNSHIP  
LAKEVILLE ELEMENTARY  
14059 SR 226  
NPDES 3PT00062

Mr. Mark VanSickle, Maintenance Supervisor  
West Holmes Local Schools  
28 West Jackson Street  
Millersburg, OH 44654

Dear Mr. VanSickle:

On September 18, 2007, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a good color and the clarifier effluent was clear. All treatment processes were in good operation and maintenance condition.

A review of your monthly operating reports covering the period September 2006 through August 2007 revealed the following effluent violation.

**September 2006**

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residu	1D Conc	0.019	.14	9/18/2006

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Kraig Bucklew, Holmes County Health Department  
Kevin Dean

File: Semi-Public/Lakeville Elementary