



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 4, 2009

RE: HOLMES COUNTY  
HARDY TOWNSHIP  
HOLMES SIDING  
6767 CR 624  
NPDES 3PR00337

Mr. Dan Mast  
Holmes Siding Contractors  
6783 CR 624  
Millersburg, OH 44654

Dear Mr. Mast:

On June 3, 2009, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the mixed liquor in the aeration tank had a light brown color. The clarifier was producing a clear effluent. The surface sand filter beds were in very good condition, however, the contents of the chlorine contact tank were cloudy.

A review of your discharge monitoring reports (DMRs) covering the period March 2008 through April 2009, revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2008	001	Total Suspended Solids	30D Conc	12	17.	3/1/2008
March 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	3.75	3/1/2008
June 2008	001	Total Suspended Solids	30D Conc	12	209.	6/1/2008
June 2008	001	Total Suspended Solids	7D Conc	18	209.	6/1/2008
June 2008	001	Total Suspended Solids	30D Qty	0.068	.09651	6/1/2008
August 2008	001	Total Suspended Solids	30D Conc	12	13.	8/1/2008
December 2008	001	Total Suspended Solids	30D Conc	12	14.	12/1/2008
March 2009	001	Total Suspended Solids	30D Conc	12	41.	3/1/2009
March 2009	001	Total Suspended Solids	7D Conc	18	41.	3/8/2009

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Kraig Bucklew, Holmes County Health Department  
Kevin Dean