



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 24, 2008

RE: HOLMES COUNTY
HARDY TOWNSHIP
HOLMES SIDING
6767 CR 624
NPDES 3PR00337

Dan Mast
Holmes Siding Contractors
6783 CR 624
Millersburg, OH 44654

Dear Mr. Mast:

On March 18, 2008, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the treatment plant was producing what appeared to be a marginal quality effluent. The aeration tank is being operated on a timer. The contents of the clarifier were turbid. The surface sand filter beds were in very good condition and the contents of the chlorine contact tank were cloudy.

A review of your self-monitoring reports covering the period June 2007 through February 2008, revealed the following effluent violation.

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2007	001	Fecal Coliform	7D Conc	2000	3300.	8/15/2007

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Should you have any questions or comments regarding this letter, please contact this office at (330)963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS:bo

pc: Holmes County Health Department, Attn: Kraig Bucklew

File: Semi-Public/Holmes Siding