



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 21, 2008

RE: HOLMES COUNTY
SALT CREEK TOWNSHIP
THREE M, LTD.
7488 SR 241
NPDES 3PR00251

Mr. Dean Mullet
7488 SR 241
Millersburg, OH 44654

Dear Mr. Mullet:

On May 20, 2008, this office conducted a compliance evaluation inspection of the wastewater treatment system serving the above referenced facility. Present during the inspection were this writer, Kraig Bucklew of the Holmes County Health Department and Gideon Weaver, Three M, Ltd.

The existing sewage treatment system consists of a 3,500 gpd extended aeration package plant with a 500 gallon trash trap, 3,500 gallon aeration tank, dosing chamber, 298 square foot surface sand filter, and a chlorine contact tank with a tablet chlorinator and dechlorinator. The system discharges to an unnamed tributary to Martins Creek.

At the time of the inspection, the treatment system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a good brown color. The contents of the clarifier were turbid and solids were noted along the effluent weir. The surface sand filter beds were covered with solids. The contents of the chlorine contact tank were clear.

A review of your self-monitoring reports covering the period May 2007 through March 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2007	001	Total Suspended Solids	30D Conc	12	23.	5/1/2007
May 2007	001	Total Suspended Solids	7D Conc	18	23.	5/22/2007

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

cc: Kraig Bucklew, Holmes County Health Department

File: Semi-Public/Three M Associates, Ltd.