



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 18, 2008

RE: HOLMES COUNTY
MONROE TOWNSHIP
WEST HOLMES HIGH SCHOOL
10901 SR 39
NPDES 3PT00068

Mr. Mark VanSickle, Maintenance Supervisor
West Holmes Local Schools
28 West Jackson Street
Millersburg, OH 44654

Dear Mr. VanSickle:

On September 17, 2008, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the system was producing what appeared to be a satisfactory quality effluent. The mixed liquor in the aeration tank had a very good color, and the upflow clarifier effluent was clear. The surface sand filters were in very good condition and the contents of the chlorine contact tank were clear.

A review of your discharge monitoring reports (DMRs) covering the period September 2007 through August 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2008	001	Dissolved Oxygen	1D Conc	6.0	5.65	8/5/2008
August 2008	001	Dissolved Oxygen	1D Conc	6.0	5.99	8/18/2008

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mlh

pc: Holmes County Health Department, Attn: Kraig Bucklew
Kevin Dean

File: Semi-Public/West Holmes High School