



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 29, 2007

RE: HOLMES COUNTY
WASHINGTON TOWNSHIP
BUCKEYE DELI
122 SR 39
NPDES 3PR00447

Mr. Steve Miller
Buckeye Deli
122 S.R. 39
Nashville, OH 44661

Dear Mr. Miller:

On October 23, 2007, this office conducted an inspection of the wastewater treatment plant serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the blowers were not running as the plant is being operated on a timer. The contents of the clarifier were clear. However, there were some solids on the surface of the clarifier. The trash trap appeared to have been recently pumped.

A review of your self-monitoring reports covering the period January 2007 through September 2007 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2007	001	Total Suspended Solids	30D Conc	30	40.	3/1/2007
March 2007	001	Dissolved Oxygen	1D Conc	6.0	4.24	3/2/2007
June 2007	001	Dissolved Oxygen	1D Conc	6.0	2.85	6/4/2007
August 2007	001	Dissolved Oxygen	1D Conc	6.0	2.38	8/1/2007

The Schedule of Compliance contained in your NPDES permit (Part I,C) requires that a permit-to-install (PTI) application for treatment system improvements is submitted to this office by July 1, 2007. To date, this office has not received this application. Therefore, you are in noncompliance with your NPDES permit.

You are directed to respond to this office, in writing, within 15 days from the date of this letter as to the measures that will be taken to bring your facility into compliance.

Please be advised that failure to comply with the requirements of your NPDES permit will result in an enforcement action which will include monetary penalties.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

cc: Kraig Bucklew, Holmes County Health Department

File: Semi-Public/Buckeye Deli

