



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 26, 2007

RE: SELF-MONITORING REPORT VIOLATION
LAKE COUNTY
LAMUTH MIDDLE SCHOOL
OHIO EPA PERMIT NO. 3PT00120
NPDES PERMIT NO. OH0134716

Mr. Michael Shoaf, Superintendent
Painesville Township Board of Education
585 Riverside Drive
Painesville, OH 44077

Dear Mr. Shoaf:

This office has recently reviewed your self-monitoring reports covering the month of April 2007 for the referenced facility. Our review indicates violations of the terms and conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	4.5	14.63	4/22/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.204	.66449	4/22/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	3.0	14.63	4/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.136	.66449	4/1/2007

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions or comments regarding this notification, please contact this writer at (330) 963-1183.

Sincerely,

Marie Underwood
Environmental Engineer
Division of Surface Water

MU/mt