



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

November 28, 2007

RE: SELF-MONITORING REPORT VIOLATION  
LAKE COUNTY  
LAMUTH MIDDLE SCHOOL  
WASTEWATER TREATMENT PLANT  
OEPA PERMIT NO. 3PT00120  
NPDES PERMIT NO. OH0134716

Mr. Michael Shoaf, Superintendent  
Painesville Township Board of Education  
585 Riverside Drive  
Painesville, OH 44077

Dear Mr. Shoaf:

This office has recently reviewed your self-monitoring reports covering the month of September 2007 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	5.18	9/15/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.068	.23528	9/15/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	5.18	9/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.045	.23528	9/1/2007

Violation Date	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported
9/1/2007	001	50060	Chlorine, Total Residual	1/2Weeks	1	0
8/1/2007	001	50060	Chlorine, Total Residual	1/2Weeks	1	0

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions or comments regarding this notification, please contact this writer at (330) 963-1183.

Sincerely,

Marie Underwood, P.E.  
Environmental Engineer  
Division of Surface Water

MU/mt