



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 28, 2008

Re: DISCHARGE MONITORING
REPORT VIOLATIONS
LAKE COUNTY
LAMUTH MIDDLE SCHOOL
WASTEWATER TREATMENT PLANT
OEPA Permit No. 3PT00120
NPDES Permit No. OH0134716

Mr. James Kalis, Superintendent
Painesville Township Board of Education
585 Riverside Drive
Painesville, OH 44077

Dear Mr. Kalis:

This office has recently reviewed your discharge monitoring reports covering the months of April 2008 through June 2008 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of non-compliance are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.6	5/13/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.5	12.53	5/8/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.068	.56911	5/8/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	12.53	5/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.045	.56911	5/1/2008

Please be advised that such instances of non-compliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Please inform this office, in writing, within 10 days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions or comments regarding this notification, please contact this writer at (330) 963-1183.

Sincerely,

Marie Underwood, P.E.
Environmental Engineer
Division of Surface Water

MU/mh