



Mr. David Allen Miller  
Schrocks Woodcrafts, Inc.  
June 4, 2009  
Page 2

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2007	001	Nitrogen, Ammonia (NH3)	30D Qty	0.045	.11635	12/1/2007
December 2007	001	Nitrogen, Ammonia (NH3)	7D Conc	4.5	11.6	12/8/2007
December 2007	001	Nitrogen, Ammonia (NH3)	7D Qty	0.068	.11635	12/8/2007
March 2008	001	Total Suspended Solids	30D Conc	12	20.	3/1/2008
March 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	38.3	3/1/2008
March 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.045	.3211	3/1/2008
March 2008	001	CBOD 5 day	30D Conc	10	13.	3/1/2008
March 2008	001	Total Suspended Solids	7D Conc	18	20.	3/22/2008
March 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	4.5	38.3	3/22/2008
March 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	0.068	.3211	3/22/2008
June 2008	001	Chlorine, Total Residu	1D Conc	0.019	206.	6/9/2008
March 2009	001	Total Suspended Solids	30D Conc	12	21.	3/1/2009
March 2009	001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	30.3	3/1/2009
March 2009	001	Nitrogen, Ammonia (NH3)	30D Qty	0.045	.1882	3/1/2009

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.  
Environmental Engineer  
Division of Surface Water

DWS/mt

cc: Kraig Bucklew, Holmes County Health Department  
Ivan Schrock, President, Schrocks Woodcrafts

File: Semi-Public/Schrocks Woodcrafts Plant II