



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 4, 2008

RE: HOLMES COUNTY
WALNUT CREEK TOWNSHIP
WALNUT CREEK MENNONITE CHURCH
NPDES 3PR00425

Mr. Mike Hershberger
Walnut Creek Mennonite Church
P.O. Box 182
Walnut Creek, OH 44687

Dear Mr. Hershberger:

On October 29, 2008, this office conducted an inspection of the wastewater treatment system serving the above referenced facility. Present during the inspection were this writer and Kraig Bucklew of the Holmes County Health Department.

At the time of the inspection, the mixed liquor in the aeration tank had a good color. The clarifier was producing a clear effluent. The gravel in the surface sand filter beds must be replaced with Ohio EPA approved filter sand. The contents of the chlorine contact tank were clear.

A review of your discharge monitoring reports (DMRs) covering the period April 2008 through October 2008 revealed the following effluent violation:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2008	001	Dissolved Oxygen	1D Conc	6.0	4.43	6/3/2008

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mlh

pc: Holmes County Health Department, Attn: Kraig Bucklew

File: Semi-Public/Walnut Creek Mennonite Church