



**Environmental
Protection Agency**

Robert R. Corcoran, Governor
Mark L. Taylor, Lt. Governor
Amanda J. Adams, Director



October 15, 2012

Michelle D. Henson
Speedway LLC
500 Speedway Drive
Enon, OH 45323

GEAUGA COUNTY
SPEEDWAY 3512 PWS
NON-COMMUNITY, TRANSIENT PWS
PWS ID # OH2865112
VIO ID: 7290308

Subject: Rescinding Violation – TCR

Dear Ms. Henson:

Your public water system was issued a notice of violation of Rule 3745-81-21 of the Ohio Administrative Code (OAC) on 9/5/2012 for the monitoring period of third quarter 2012. A total coliform routine positive sample was collected on 8/8/2012 but the result was not reported to you from the lab until 8/16/2012 and Ohio EPA until 9/4/2012. Once informed of the requirement for repeat samples, you collected repeats on 8/21/2012. Those results were not reported to Ohio EPA until 9/6/2012 resulting in a violation for your water system.

The violation has been rescinded and the public notice sent with the notice of violation referenced above does not need to be issued.

OAC 3745-81-31 and 3745-89-08 require results to be reported by the tenth day following the month the sample was collected. Further, OAC 3745-89-08 requires the laboratory to report all positive, all repeat sample results and all samples required by OAC 3745-81-42 (Ground Water Rule) no later than the end of the next business day after the result was obtained. The samples were not reported in accordance with the above rules and this is considered a reporting violation. The information provided to this office regarding the time line of your receipt of the results has been provided to our Central Office for further investigation regarding possible violations the certified laboratory may have incurred due to late reporting.

Per our telephone conversation, I understand you will ensure future sample results are submitted as required. If you have any questions, please contact this office at 330-963-1200.

Sincerely,

Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

cc: Geauga County Health Department
Test America Laboratories, Inc.