



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



September 17, 2012

NOTICE OF VIOLATION

Sharon Koon, Mayor
Village of Murray City
P.O. Box 241
Murray City, OH 43144

Hocking County
Murray City Village

Community Public Water System
PWS ID: OH3700803

Dear Mayor Koon:

The Public Water System serving the Village of Murray City is in violation of the Ohio Administrative Code (OAC) for failure to submit the following Monthly Operating Report requirement.

Chlorine for Community PWS (frequency)

OAC Rule 3745-83-01(H) (1) (b) requires the public water system owner to **monitor both the free and combined chlorine residuals at least once every day.**

The Village of Murray City **did not perform chlorine monitoring** for 24 days during the month of August 2012.

If you have any questions please call me at 740-380-5207 or via email to sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace
Environmental Engineer

SW/cb

ec: SEDO DDAGW AA (State Violation)

cc: Ralph Davis, Operator
639 Walnut St
Nelsonville, OH 45764