



**Environmental Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

**NOTICE OF VIOLATION**

October 15, 2011

RE: PORTAGE COUNTY  
SOUTHEAST HIGH SCHOOL  
NTNC WATER SYSTEM  
PWS ID # OH6753512

Mr. Henry Michael  
8245 Tallmadge Rd  
Ravenna, Ohio 44266

**CERTIFIED MAIL**

Dear Mr. Michael:

This letter is notification that the Southeast High School public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(F)(2)(a) which states, "A public water system that provides water treated with chlorine shall monitor for free or combined chlorine at least once every day that water is available to the public **at each entry point to the distribution system and a representative point or points in the distribution system.**"

This violation of the OAC is based upon information submitted by the Southeast High School PWS as reported on Monthly Operating Report (MOR) #5002 for the month of **August 2012**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was not recorded.

Reporting Month	Number of days the free chlorine residual was not reported at entry point	Number of days the free chlorine residual was not reported in distribution
June	0	13
July	0	14
August	0	15

**Please provide a written explanation within 30 days of the date of this letter detailing how this issue is being addressed.**

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,

Laurel Hricik  
Environmental Specialist  
Division of Drinking and Ground Waters

LH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Kim Ethers, Ohio EPA, NEDO, DDAGW