Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

NOTICE OF VIOLATION

October 15, 2011

RE: PORTAGE COUNTY
SOUTHEAST MIDDLE SCHOOL
NTNC WATER SYSTEM
PWS ID # OH6784912

Mr. Henry Michael
8245 Tallmadge Rd
Ravenna, Ohio 44266

CERTIFIED MAIL

Dear Mr. Michael:

This letter is notification that the Southeast Middle School public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01(F)(2)(a) which states, *"A public water system that provides water treated with chlorine shall monitor for free or combined chlorine at least once every day that water is available to the public at each entry point to the distribution system and a representative point or points in the distribution system. A non-community ground water system whose distribution system is solely interior plumbing in a single building only needs to collect one representative sample daily."*

This violation of the OAC is based upon information submitted by the Southeast Middle School PWS as reported on Monthly Operating Report (MOR) #5002 for the month of **August 2012**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was not recorded.

Reporting Month	Number of days the free chlorine residual was not reported
June	13
July	14
August	16

Please provide a written explanation within 30 days of the date of this letter detailing how this issue is being addressed.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,

Laurel Hricik
Environmental Specialist
Division of Drinking and Ground Waters

LH/ams

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Kim Etters, Ohio EPA, NEDO, DDAGW

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov