



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



**NOTICE OF VIOLATION – ACTION REQUIRED**

October 17, 2012

Mr. Steven R. Ureel  
Hillcrest Estates Mobile Home Court  
1120 North Main Street  
Rochester, Michigan 48307

Hardin County  
Hillcrest Estates Mobile Home Court  
Community PWS  
PWS ID: OH3301212  
STU ID: 3354893

Dear Mr. Ureel:

The Public Water System serving Hillcrest Estates Mobile Home Court is in violation of Ohio Revised Code (ORC) Chapter 6109 as follows:

In violation of Ohio Administrative Code (OAC) Rule 3745-82-02, the public water system has exceeded the secondary standard for iron, which is 0.3 mg/L. There were 2 weeks during the month of September, 2012 in which iron exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for iron are as follows:

Public water systems shall use the monitoring required by OAC Rule 3745-83-01(F)(5) to determine compliance with the secondary maximum contaminant level for iron.

A public water system shall be in violation of the secondary standard for iron when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Violation of the secondary standard for iron does not require public notification.

**Please review your operations to determine the reason for the exceedance and advise this office as to what corrections will be made.**


Mr. Steven R. Ureel

October 17, 2012

Page 2

If you have any questions regarding this letter, please contact me at (419) 373-3102 or via email at [Kim.Burnham@epa.state.oh.us](mailto:Kim.Burnham@epa.state.oh.us).

Sincerely,



Kimberly K. Burnham, R.S.  
Division of Drinking and Ground Waters

/cg

pc: Hardin County Health Department  
Philip Epley  
File: DDAGW – NWDO