



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Richland County
Rocky's Truck and Trailer Service
NPDES Permit

November 27, 2007

Mr. David Eckstein, President
M&D Real Estate Investments
1666 Westover Lane
Mansfield, Ohio 44906

Dear Mr. Eckstein,

On November 1, 2007, an inspection was made of the wastewater treatment facilities serving Rocky's Truck and Trailer Service located at 4732 U.S. 30, Springfield Township, Richland County. At the time of the inspection all major components of the treatment system appeared to be operating normally. No major concerns were noted.

It was observed that the dechlorination tablet feeder had been installed. Proper application of the dechlorination tablets should help prevent future violations of the residual chlorine limit. The return sludge line appeared to be operating normally and the clarifier had several inches of clarity at the surface.

Our office has received your monthly operating reports (MORs) for the months of May through September 2007. A review of the data submitted shows several violations of the limits contained in your NPDES permit. The majority of the violations were for exceeding the limits for Residual Chlorine and Dissolved Oxygen. It was observed that no violations for CBOD, TSS, and Ammonia had occurred since July. This would seem to indicate that the waste is receiving sufficient biological treatment through the system. Closer attention to the disinfection units should help prevent violations associated with operation of these units.

If you have any questions please call me at 419-373-3070.

Sincerely,

Walter Ariss
Environmental Specialist II
Division of Surface Water

/llr

pc: ~~DSW=NWDO File~~
Richland County Health Department
Gary Hoam, Chem Tech Consultants

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION
WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2PR00225

Facility Name Roddy Truck & Trailer Expiration Date 6/30/2011

Facility Address 4732 Lincoln Highway Date 11/1/02 Time 3:00 am

City Crestline County Richland Township Sandusky

Name and Address of Owner M+O Real Estate

Person Contacted _____ Owner Phone _____

Flow: Design 2,000 GPD Present 400 GPD (metered - estimated)

Trib. Pop. _____ (actual - estimated) Weather at time of inspection: Temp 62° Sunny

OEPA Personnel Walter Aris District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: unimpaired trib. stream

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

- a. Plant has _____ excellent good _____ fair _____ poor operation
- b. Plant has _____ excellent good _____ fair _____ poor maintenance
- c. Sand filters have _____ excellent good _____ fair _____ poor maintenance

d. Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
- (2) _____ organic/ solids overload
- (3) _____ personnel inefficiency
- (4) _____ equipment failure
- (5) _____ wastes
- (6) _____

Disinfection: (Required May 1 thru Oct.31.)

IN	OUT	
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Chlorination Tablets
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Dechlorination Tablets
<input type="checkbox"/>	<input type="checkbox"/>	U.V.

4. Yes No Compliance with NPDES Permit

Periodic Violations Y N Parameters: _____
Chronic Violations Y N Cl₂, O₃, Fecal

5. Adequate plant safety

6. Operation and Maintenance Service Name Chem-Tech

Frequency of Visits _____ ?

Facility Name: Rocky's Track & Trailer

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	<input checked="" type="checkbox"/>	Trash Trap	Pumping Frequency: ?
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment	<input checked="" type="checkbox"/>	Plant Timer <u>Y</u> N	Cycle Time:
		Motor/ Blower Unit <i>running</i>	
Secondary Treatment	<input checked="" type="checkbox"/>	Aeration Tank	Color: <i>okay</i> Adequate Aeration: <u>Y</u> N
Final Settling	<input checked="" type="checkbox"/>	Clarifier	<i>good</i>
	<input checked="" type="checkbox"/>	Sludge Return	In <input checked="" type="checkbox"/> Out <u> </u>
	<input checked="" type="checkbox"/>	Surface Skimmer	In <u> </u> Out <input checked="" type="checkbox"/>
		Fixed Media Clarifier	
Tertiary Treatment	<input checked="" type="checkbox"/>	Surface Sand Filter	<i>both filters clean</i>
		Polishing Pond	
		Other	
Disinfection	<input checked="" type="checkbox"/>	Chlorine Tube Feeder	<i>okay</i>
	<input checked="" type="checkbox"/>	Dechlorination Tube Feeder	<i>okay</i>
		Ultraviolet (UV)	
Flow Metering?		Elapsed Pump Time	
		Recorder (continuous total)	
Pumps		Raw Wastewater (type)	
	<input checked="" type="checkbox"/>	Sand Filter Effluent Dosing	<i>okay</i>
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	<input checked="" type="checkbox"/>	Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	