



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Richland County
Rocky's Truck and Trailer Service
NPDES Permit

June 3, 2009

Mrs. Shelly Fisher
M&D Real Estate Investments
2045 Millsboro Road
Mansfield , Ohio 44906

Dear Mrs. Fisher,

On May 13, 2009, an inspection was made of the wastewater treatment facilities serving your property located at 4732 Lincoln Highway, Springfield Township, Richland County. At the time of the inspection all major components of the treatment system appeared to be operating normally. No major concerns were noted.

It was noted that a large amount of sludge has accumulated behind both the inlet and outlet baffles in the clarifier tank. The sludge behind the baffles should be cleaned the next time sludge is removed from the treatment plant.

Our office has received your discharge monitoring reports for the months of November 2008 through April 2009. A review of the data submitted revealed only one violation of the limits contained in your NPDES permit. This was for exceeding the final pH in April 2009.

A copy of our completed inspection report has been enclosed for your review. If you have any questions please call me at 419-373-3070.

Sincerely,

Walter Ariss
Environmental Specialist II
Division of Surface Water

/lb

Enclosure

pc: ~~DSW=NWDO~~
Lonnie McGhee, McGhee's Technical Water Service Inc. w/enclosure

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION
 WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2PR 00225

Facility Name YHD Real Estate Expiration Date 6/30/2011

Facility Address 4732 Lincoln Highway Date 5/13/09 Time 2:30 am Kpm

City Crestline County Richland Township _____

Name and Address of Owner Shelly Fisher 2045 Hillside Rd.

Person Contacted _____ Owner Phone _____

Flow: Design 2,000 GPD Present 400-800 GPD (metered - estimated) time

Trib. Pop. _____ (actual - estimated) Weather at time of inspection: Temp 65° sunny

OEPA Personnel Walter Ariss District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: unnamed trib. between Creek - not observed

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has _____ excellent good _____ fair _____ poor operation
 b. Plant has _____ excellent good _____ fair _____ poor maintenance
 c. Sand filters have _____ excellent good _____ fair _____ poor maintenance

d. Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
 (2) _____ organic/ solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

Disinfection: (Required May 1 thru Oct.31.)

IN	OUT	
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Chlorination Tablets
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Dechlorination Tablets
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	U.V.

Yes No

4. Compliance with NPDES Permit

Periodic Violations Y N Parameters: pH

Chronic Violations _____

5. Adequate plant safety

6. Operation and Maintenance Service Name Mebbee's TWSI

Frequency of Visits Monthly

Facility Name: Hold Real Estate

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	<input checked="" type="checkbox"/>	Trash Trap	Pumping Frequency: ?
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment	<input checked="" type="checkbox"/>	Plant Timer <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Motor/ Blower Unit <i>running</i>	Cycle Time: <i>one in service</i> <i>other as backup</i>
Secondary Treatment	<input checked="" type="checkbox"/>	Aeration Tank <i>odor not excessive near plant</i>	Color: <i>good color</i> Adequate Aeration: Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
Final Settling	<input checked="" type="checkbox"/>	Clarifier	<i>fairly clear, slight layer of scum</i>
	<input checked="" type="checkbox"/>	Sludge Return	In <input checked="" type="checkbox"/> Out <input type="checkbox"/>
	<input checked="" type="checkbox"/>	Surface Skimmer	In <input type="checkbox"/> Out <input checked="" type="checkbox"/> <i>use to skim off scum</i>
		Fixed Media Clarifier	
Tertiary Treatment	<input checked="" type="checkbox"/>	Surface Sand Filter	<i>very clear</i>
		Polishing Pond	
		Other	
Disinfection	<input checked="" type="checkbox"/>	Chlorine Tube Feeder	<i>okay</i>
	<input checked="" type="checkbox"/>	Dechlorination Tube Feeder	<i>okay</i>
		Ultraviolet (UV)	
Flow Metering	<input checked="" type="checkbox"/>	Elapsed Pump Time	<i>on filter dosing station</i>
		Recorder (continuous total)	
Pumps		Raw Wastewater (type)	
	<input checked="" type="checkbox"/>	Sand Filter Effluent Dosing	<i>okay</i>
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	<input checked="" type="checkbox"/>	Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	