



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Richland County
Skyway East Restaurant
NPDES Permit

November 7, 2007

Mr. Bernard Smith, Owner
Skyway East Restaurant
2461 Emma Lane
Mansfield, Ohio 44903

Dear Mr. Smith:

On October 11, 2007, an inspection was made of the wastewater treatment facilities serving the Skyway East Restaurant located at 2461 Emma Lane, Mansfield, Richland County. At the time of the inspection the plant appeared to be operating normally. No major concerns were noted.

A review of the monthly operating reports submitted to our office revealed that the flow rate is being reported under code 50050-Million Gallons Per Day. Your permit requires that flow rate data be reported under code 00056- Gallons Per Day. Please discuss this with McGhee's Technical Water Services your certified operator.

Please be aware that your NPDES permit contains a compliance schedule for plant upgrades or tie in to the Richland County sanitary sewer system. You indicated in a letter received by our office on March 7, 2007, that your intention is to tie into the Richland County sewer. A Permit to Install for this project is to be submitted to our office for approval no later than January 1, 2008.

Please call me at 419-373-3070 if you have any questions.

Sincerely,

Walter Ariss
Environmental Specialist II
Division of Surface Water

/csl

Enclosure

pc: DSW-NWDO

Lonnie McGhee, McGhee's TWSI w/enclosure

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION
WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2P00223

Facility Name Skyway East Expiration Date 6/30/2011

Facility Address Emma Ln Date 10/11/07 Time 12:00 am (pm)

City Mansfield County Richland Township _____

Name and Address of Owner Bernard Smith

Person Contacted _____ Owner Phone _____

Flow: Design 1,800 GPD Present 500 ? GPD (metered - estimated)

Trib. Pop. _____ (actual - estimated) Weather at time of inspection: Temp 65° rain

OEPA Personnel Walter Ariss District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate	<input checked="" type="checkbox"/>	Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: unmarked to Charles Hill Lake

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild	<input checked="" type="checkbox"/>					
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has _____ excellent _____ good fair _____ poor operation
 b. Plant has _____ excellent _____ good fair _____ poor maintenance
 c. Sand filters have _____ excellent _____ good _____ fair _____ poor maintenance
no filters

d. Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
 (2) organic/ solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

Disinfection: (Required May 1 thru Oct.31.)

IN OUT

Chlorination Tablets _____
 Dechlorination Tablets _____
 U.V. _____

no disinfection

Yes No

4. _____ Compliance with NPDES Permit

Periodic Violations Y N Parameters: _____

Chronic Violations _____

5. _____ Adequate plant safety

6. _____ Operation and Maintenance Service Name McGhee's TWSF

Frequency of Visits ?

Facility Name: Skyway East

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	<input checked="" type="checkbox"/>	Trash Trap	Pumping Frequency: ?
	<input checked="" type="checkbox"/>	Grease Trap	Pumping Frequency: ?
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment	<input checked="" type="checkbox"/>	Plant Timer <u>Y</u> <input checked="" type="checkbox"/> <u>N</u> Motor/ Blower Unit <i>running</i>	Cycle Time:
Secondary Treatment	<input checked="" type="checkbox"/>	Aeration Tank	Color: <i>tan color, heavy foam</i> Adequate Aeration: <u>Y</u> <input checked="" type="checkbox"/> <u>N</u>
Final Settling	<input checked="" type="checkbox"/>	Clarifier	<i>some foam in clarifier sludge being in let. battle needs pumped</i>
	<input checked="" type="checkbox"/>	Sludge Return	In <input checked="" type="checkbox"/> Out <u>tan color</u>
	<input checked="" type="checkbox"/>	Surface Skimmer	In <u>Out</u> <input checked="" type="checkbox"/>
		Fixed Media Clarifier	
Tertiary Treatment		Surface Sand Filter	
		Polishing Pond	
		Other	
Disinfection		Chlorine Tube Feeder	
		Dechlorination Tube Feeder	
		Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
		Recorder (continuous total)	
Pumps		Raw Wastewater (type)	
		Sand Filter Effluent Dosing	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal		Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	