



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

RE: Notice of Violation
Van Wert County
Boyd Theaters
Ohio EPA Permit No. 2PR00213
NPDES Permit No. OH0135992

June 17, 2008

Mr. James Boyd
Owner
Boyd Theaters
10721 W. Ridge Road
Van Wert, OH 45891

Dear Mr. Boyd:

We are in receipt of your self-monitoring report covering the months of January 2008 through March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, feel free to contact me at (419) 373 - 3022.

Sincerely,

Justin A. Williams
Division of Surface Water

/lb

Enclosure

~~PC-W/Enclosure-NWDO-DSW-File~~

Get New Data

Violations for Boyd Theaters - January thru March 2008

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00213*AD	March 2008	001	00610	Nitrogen, Ammonia (NH3 30D Conc		3.0	20.6	3/1/2008
2PR00213*AD	March 2008	001	00610	Nitrogen, Ammonia (NH3 30D Qty		0.023	.05536	3/1/2008
2PR00213*AD	March 2008	001	00610	Nitrogen, Ammonia (NH3 1D Conc		4.5	20.6	3/13/2008
2PR00213*AD	March 2008	001	00610	Nitrogen, Ammonia (NH3 1D Qty		0.034	.05536	3/13/2008