



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Van Wert County  
Convoy WWTP  
Ohio EPA Permit No. 2PB00005  
NPDES Permit No. OH0023493

June 2, 2010

Mr. Terry Crowle  
WWTP Superintendent  
Village of Convoy  
P. O. Box 310  
Convoy, Ohio 45832

Dear Mr. Crowle:

We are in receipt of your self-monitoring report covering the months of January through March 2010, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.

We have received your email dated March 16, 2010, regarding the referenced violation and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.



Mr. Terry Crowle  
June 2, 2010  
Page 2

If there are any questions, feel free to contact me at (419) 373-3022.

Sincerely,



Justin A. Williams  
Division of Surface Water

/llr

Enclosure

pc-w/Enclosure: \_ \_ DSW-NWDO.File \_ )

Get Flow Data

Violation for Convey WWTTP - January - March 2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00005*JD	February 2010	001	00530	Total Suspended Solids	7D Qty	14.0	16.7796	2/22/2010