



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Notice of Violation  
Van Wert County  
Convoy WWTP  
Ohio EPA Permit No. 2PB00005  
NPDES Permit No. OH0023493

October 5, 2010

Mr. Terry Crowle  
WWTP Superintendent  
Village of Convoy  
P. O. Box 310  
Convoy, Ohio 45832

Dear Mr. Crowle:

We are in receipt of your self-monitoring report covering the months of April through June 2010 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on a separate sheet.

We have received your email dated May 28, 2010, regarding the referenced violation and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, feel free to contact me at (419) 373-3022.

Sincerely,

Justin A. Williams  
Division of Surface Water

/cs  
Enclosure

~~pcw/Enclosure-NWDO-DSW-File~~

Get New Data

Violation for Convey LLUP - April - June 2010

| Permit No   | Reporting Period | Station | Reporting Code | Parameter              | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|------------------------|------------|-------|----------------|----------------|
| 2PB00005*JD | May 2010         | 001     | 00530          | Total Suspended Solids | 30D Qty    | 9.1   | 9.63415        | 5/1/2010       |