



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 23, 2011

George Sicaras
H&G LLC
2988 North High Street
Columbus, OH 43202

**Re: Notice of Violation
H&G Property Mass Fill, Franklin County
Permit Number: 4GCD00074 *AG**

Dear Mr. Sicaras:

This letter is written regarding a storm water inspection that I conducted at H&G Property Mass Fill located west of Alton Darby Creek Road, north of Roberts Road Hilliard, Ohio on August 19, 2011. The reason for the inspection was a result of a storm water complaint that dewatering activities were not being properly done at your site. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Storm water runoff is collecting along Alton Darby Creek Road and is causing silt fence to collapse on an adjacent construction project. It is recommended that the standing water be pumped to a nearby grassy area according to your storm water pollution prevention plan.
- Filling activities were being conduct at the site.
- It does not appear that your contractor applied as a co-permittee. Please insure that you are compliant with your permit by having your contractor apply as a co-permittee of the storm water general permit.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at greg.sanders@epa.state.oh.us.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO
Mark Waite, Franklin County Engineers Office
Clyde Seidle, City of Hilliard
James Akins, EMH&T, Inc.

GS/nsm H&G Property Mass Fill, August 19, 2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov