



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 18, 2011

Jason Francis
MI Homes of Central Ohio
3 Easton Oval
Suite 340
Columbus, OH 43219

**Re: Construction Storm Water Inspection at Oldstone Crossing Section 3
Franklin County
Permit Number: 4GCO00014 *AG**

Dear Mr. Francis:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Lindsey Boaz of the Ohio EPA at Oldstone Crossing located at Hard Road and Linworth Road on August 9, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- There were storm drains noted on site which require inlet protection, specifically the storm drains located on Southview Court and the storm drain noted in Figure 1. Please take immediate corrective measures to minimize sediment laden discharges to waters of the state.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



FOR HK

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW / CDO

HK/nsm Oldstone Crossing Section 3 8-9-2011

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov



Figure 1: Sediment discharging to storm drain