



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 11, 2011

James Waterman  
Samuel Strapping Systems, Inc.  
1455 James Parkway  
Heath, OH 43056

**Re: Construction Storm Water Inspection at Samuel Strapping Systems / Licking County  
Permit Number: 4GR00552\*DG**

Dear Mr. Waterman:

This letter is written regarding a storm water inspection conducted by Daelann Farnlacher and Greg Mann of the Ohio EPA at Samuel Strapping Systems located at 1455 James Parkway, Heath, Ohio 43056 on June 24, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- During the inspection, our staff indicated that barren areas are currently routed to large impoundment. Please verify in your response letter.
- Please ensure a concrete washout waste area is established that does not result in discharges to storm sewer systems or waters of the state (See Figure 1).

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Samuel Strapping Systems (Industrial Site)

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)



Samuel Strapping Systems  
Licking River Watershed  
Photo By: Deelann Farnlecher  
6/24/11  
Discharge to storm sewer system

Figure 1: Concrete waste discharge