



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

Steve Geiger
Geiger Excavating Inc.
65 Southwind Drive
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Bedford II Landfill Cover
Franklin County
Permit Number: 4GC03047*AG**

Dear Mr. Geiger:

This letter is written regarding the storm water inspection I conducted at Bedford II Landfill Cover located at Enterprise Drive in Gahanna, Ohio on August 27, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted;

Sediment and Erosion Controls:

- Our staff observed the retention pond around the inlet has become overburdened with sediment. Please be aware sediment traps must be utilized for areas of concentrated flow and must be sized with a required sediment storage volume per the General Permit. These sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity.
- Please be aware all barren areas must be seeded and mulched prior to the onset of winter.

Maintenance:

- The sediment controls implemented on this site will require maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on-site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Steve Geiger
Geiger Excavating Inc.
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO