



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.ohio.gov

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Van Wert County
Ohio City WWTP
Ohio EPA Permit No. 2PB00030
NPDES Permit No. OH0023396

June 2, 2010

Mr. Jeff Krugh
WWTP Superintendent
Village of Ohio City
P.O. Box 248
Ohio City, Ohio 45874

Dear Mr. Krugh:

We are in receipt of your self-monitoring reports covering the months of January through March 2010, for the Ohio City WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in March 2010, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction).

Mr. Jeff Krugh
June 2, 2010
Page 2

For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically; help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (419) 373-3022.

Yours truly,


Justin A. Williams
Division of Surface Water

/llr

Enclosure

⌘pc w/Enclosure: - [DSW-NWDO File]

Get New Data

Violations for Chic City WWT P - January - March 2010

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00030*HD	January 2010	001	00530	Total Suspended Solids	30D Conc	20	22.275	1/1/2010
2PB00030*HD	January 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	5.265	1/1/2010
2PB00030*HD	January 2010	001	80082	CBOD 5 day	30D Conc	10	11.2428	1/1/2010
2PB00030*HD	January 2010	001	00530	Total Suspended Solids	7D Conc	35	47.35	1/8/2010
2PB00030*HD	January 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	6.0	6.65	1/15/2010
2PB00030*HD	January 2010	001	80082	CBOD 5 day	7D Qty	8.6	8.88603	1/22/2010
2PB00030*HD	February 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	5.69	2/1/2010
2PB00030*HD	February 2010	001	80082	CBOD 5 day	30D Conc	10	12.7887	2/1/2010
2PB00030*HD	February 2010	001	80082	CBOD 5 day	7D Conc	15	16.885	2/8/2010
2PB00030*HD	February 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	6.0	6.27	2/15/2010
2PB00030*HD	February 2010	001	80082	CBOD 5 day	7D Conc	15	15.6	2/15/2010
2PB00030*HD	March 2010	001	80082	CBOD 5 day	30D Qty	5.7	7.92207	3/1/2010
2PB00030*HD	March 2010	001	80082	CBOD 5 day	7D Qty	8.6	9.84774	3/1/2010

Get New
Data

Get Data
for Selected
Permit

Facilities in Significant Non-Compliance **

Period: Oct-09 Mar-10

County	Permit #	Facility Name	Major	Station Code	Param. Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)	# Months Exceed (2)**
Van Wert	2PB00030	Ohio City WWTP			1 80082	CBOD 5 day	39	0	4

Footnotes

for Significant NonCompliance

** Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
 - a. 40% for Group 1 pollutants **plus Fecal Coliform**
 - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**-- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.