



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korteski, Director

RE: Notice of Violation  
Van Wert County  
Ohio City WWTP  
Ohio EPA Permit No. 2PB00030  
NPDES Permit No. OH0023396

November 30, 2010

Mr. Jeff Krugh  
WWTP Superintendent  
Village of Ohio City  
P.O. Box 248  
Ohio City, OH 45874

Dear Mr. Krugh:

We are in receipt of your self-monitoring reports covering the months of July through September 2010 for the Ohio City WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Yours truly,

Justin A. Williams  
Division of Surface Water  
/lb  
Enclosure

Pc w/Enclosure: ~~NWDO~~ = DSW File

Get New Data

Violations for Ohio City LeutP - July - September 2010

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00030*ID	July 2010	001	80082	CBOD 5 day	30D Conc	10.0	10.8287	7/1/2010
2PB00030*ID	August 2010	001	80082	CBOD 5 day	30D Conc	10.0	12.5462	8/1/2010
2PB00030*ID	August 2010	001	80082	CBOD 5 day	7D Qty	8.6	8.78845	8/1/2010
2PB00030*ID	September 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.859	9/1/2010
2PB00030*ID	September 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	2.3	5.2	9/15/2010
2PB00030*ID	September 2010	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	1.3	1.37774	9/15/2010