



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Notice of Violation  
Van Wert County  
Ohio City WWTP  
Ohio City WTP

February 11, 2011

Mr. Jeff Krugh  
WWTP Superintendent  
Village of Ohio City  
P. O. Box 248  
Ohio City, Ohio 45874

Dear Mr. Krugh:

We are in receipt of your self-monitoring reports covering the months of October through December 2010, for the Ohio City WWTP and the Ohio City WTP. Our review indicates violations of the conditions of both NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of both sets of self-monitoring reports for the previous six months, ending in December 2010, indicates that you are in significant non-compliance (SNC) with two effluent limitations contained in your NPDES permits. The specific instances of SNC are attached on separate sheets.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs.

Mr. Jeff Krugh  
February 11, 2011  
Page 2

For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Yours truly,

  
Justin A. Williams  
Division of Surface Water

/llr

Enclosures

~~pg w/Enclosures: DSW-NWDO File (2)~~

Permit No. Data

Ohio City WWTTP - violation October - December 2010

| Permit No.  | Reporting Period | Station | Reporting Code | Parameter  | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|------------|------------|-------|----------------|----------------|
| 2PB00030*ID | October 2010     | 001     | 80082          | CBOD 5 day | 30D Conc   | 10.0  | 11.055         | 10/1/2010      |
| 2PB00030*ID | December 2010    | 001     | 80082          | CBOD 5 day | 30D Conc   | 10.0  | 12.71          | 12/1/2010      |
| 2PB00030*ID | December 2010    | 001     | 80082          | CBOD 5 day | 7D Conc    | 15.0  | 18.52          | 12/8/2010      |
| 2PB00030*ID | December 2010    | 001     | 80082          | CBOD 5 day | 7D Conc    | 15.0  | 15.56          | 12/15/2010     |

Get New Data

Get Detail for Selected Permit

## Facilities in Significant Non-Compliance \*\*

Period: Jul-10 Dec-10

| County   | Permit # | Facility Name  | Major | Station Code | Param Code | Parameter Name | Max % Exceed | # Months Signif Exceed (1)** | # Months Exceed (2)** |
|----------|----------|----------------|-------|--------------|------------|----------------|--------------|------------------------------|-----------------------|
| Van Wert | 2PB00030 | Ohio City WWTP |       | 1            | 80082      | CBOD 5 day     | 27.1         | 0                            | 4                     |

### Footnotes

#### for Significant NonCompliance

\*\* Significant non-compliance with effluent limits occurred if one or more pollutants met the following conditions:

1. During 2 or more months, the reported effluent concentration (or computed load) for a parameter exceeded an effluent limit by:
  - a. 40% for Group 1 pollutants **plus Fecal Coliform**
  - b. 20% for Group 2 pollutants **plus pH, Temperature, whole effluent toxicity**-- or --
2. During 4 or more months, the reported concentration (or computed load) exceeded the limit by > 1%.

Note: This method differs from USEPA Significant Non-compliance (SNC) method in the following ways:

- USEPA only evaluates SNC for average limits. In above analyses, maximum and weekly limits were also considered.