



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

Jerry Brems
Licking County
20 South Second Street
Newark, OH 43055

**Re: Construction Storm Water Inspection at Etna Parkway / Licking County
Permit Number: 4GC03129*AG**

Dear Mr. Brems:

This letter is written regarding the storm water inspection I conducted at Etna Parkway located between US 40 & State Route 16 in Pataskala, Ohio on August 27, 2010. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Control:

- The majority of the site is currently paved
- All ditch checks must be maintained
- All ditches must be seeded and mulched prior to the onset of the winter months
- Large stockpiles on south end of the project must be protected from erosion prior to onset of winter months

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Etna Parkway 8-27-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director