



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 28, 2008

RE: DISCHARGE MONITORING  
REPORT VIOLATIONS  
LAKE COUNTY  
YOGI'S PLACE  
OEPA PERMIT NO. 3PR00201  
NPDES PERMIT NO. OH0126021

Mr. Jim Tylec  
3631 Fox Run Drive  
Ashtabula, OH 44004

Dear Mr. Tylec:

This office has recently reviewed your discharge monitoring reports covering the month of August 2008 for the referenced facility. Our review indicates violations of the terms and conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00400	pH	1D Conc	6.5	6.3	8/28/2008
001	00400	pH	1D Conc	6.5	6.2	8/21/2008
001	00400	pH	1D Conc	6.5	5.5	8/14/2008
001	00400	pH	1D Conc	6.5	5.1	8/7/2008

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions or comments regarding this notification, please contact this writer at (330) 963-1183.

Sincerely,

Marie Underwood, P.E.  
Environmental Engineer  
Division of Surface Water

MU/mt