



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 25, 2011

RE: FONDERLAC VILLAGE CONDOMINIUMS
NPDES PERMIT NO. 3PW00025
2011 CEI

Mr. William DiApaola, President
Fonderlac Condominium Association
1175 East Calla Road
Poland, OH 44514

Mr. DiApaola:

On January 19, 2011, this writer conducted an unannounced inspection of the wastewater treatment system for the Fonderlac Condominium Association. The intent of the inspection was to view operation and maintenance activities in preparation for renewing the NPDES Permit. A review of the compliance record for the facility was also conducted as part of this inspection.

Observations:

The treatment system was satisfactory at the time of the inspection. The aeration tank had good color and mixing. The return sludge was a medium brown color. The clarifier was free of any scum on the surface, and the effluent trough was free of any sludge or residues. The sand filters were draining freely and were free of any sludge on the surface. The dosing system activated at the time of the inspection indicating that the system was operating properly.

The effluent was free of any solids at the time of the inspection. The effluent ditch was free of any solids that would indicate previous problems. The effluent flows into a wetland area that will provide further treatment prior to the wastewater entering Evans Lake.

The daily maintenance log was reviewed. The record was current to the date of the inspection. The most recent entry to the log was dated January 18, 2011. Observations for color, odor and turbidity were logged on a daily basis as required by the NPDES Permit.



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 27, 2011

RE: FONDERLAC VILLAGE CONDOMINIUMS
NPDES PERMIT NO. 3PW00025
2011 CEI

Mr. William DiApaola, President
Fonderlac Condominium Association
1175 East Calla Road
Poland, OH 44514

Mr. DiApaola:

On January 25, 2011, a letter was sent to you documenting a recent inspection of the wastewater treatment plant. The inspection date identified in the letter was in error. Attached is a revised letter with the correct date. Please disregard the previous letter.

You can contact this writer at (330) 963-1251 or at john.kwolek@epa.state.oh.us to discuss any questions you may have.

Respectfully,

John Kwolek
District Engineer
Division of Surface Water

JK/mt

cc: Joe Mansky, Mahoning County Department of Health

Mr. William DiApaola
Fonderlac Village Condominiums
January 25, 2011
Page 2


Compliance Review

A review of the compliance record for the wastewater treatment system was conducted as part of this inspection. The period of review was April 2010 through January 2011. Following are violations listed in the Ohio EPA compliance tracking system.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2010	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.3	8/1/2010
August 2010	Nitrogen, Ammonia (NH3)	7D Conc	2.25	2.3	8/8/2010
November 2010	Total Suspended Solids	30D Conc	12	53.4	11/1/2010
November 2010	Total Suspended Solids	7D Conc	18	53.4	11/22/2010

You can contact this writer at (330) 963-1251 or at john.kwolek@epa.state.oh.us to discuss any questions you may have.

Respectfully,



John Kwolek
District Engineer
Division of Surface Water

JK/mt

cc: Joe Mansky, Mahoning County Department of Health