



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 25, 2011

RE: THE LAKE CLUB  
NPDES PERMIT NO. 3PR00219  
2011 CEI

Mr. Edward Maransky, CEO  
The Lake Club  
1140 Paulin Road  
Poland, OH 44514

Mr. Maransky:

On January 19, 2011, this writer conducted an unannounced inspection of the wastewater treatment system for The Lake Club. The intent of the inspection was to view operation and maintenance activities in preparation for renewing the NPDES Permit. A review of the compliance record for the facility was also conducted as part of this inspection.

Observations

The treatment system was satisfactory at the time of the inspection. The aeration tank had good color and mixing, and the return sludge was a medium brown color. The clarifier was free of any scum on the surface. The effluent trough had some residue on the sides and was in need of cleaning. The system was not discharging at the time of the inspection; however, water in the disinfection tank was free of any solids or scum.


Compliance Review

A review of the compliance record for the wastewater treatment system was conducted as part of this inspection. The period of review was April through December 2010. Following are violations listed in the Ohio EPA compliance tracking system.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2010	Fecal Coliform	30D Conc	1000	1240.	6/1/2010
September 2010	Total Suspended Solids	30D Conc	12	14.8	9/1/2010

You may contact this writer at (330) 963-1251 or at [john.kwolek@epa.state.oh.us](mailto:john.kwolek@epa.state.oh.us) to discuss any questions you may have.

Respectfully,

  
John Kwolek  
District Engineer  
Division of Surface Water

JK/mt

cc: Joe Mansky, Mahoning County Department of Health



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 27, 2011

RE: THE LAKE CLUB  
NPDES PERMIT NO. 3PR00219  
2011 CEI

Mr. Edward Maransky, CEO  
The Lake Club  
1140 Paulin Road  
Poland, OH 44514

Mr. Maransky:

On January 25, 2011, a letter was sent to you documenting a recent inspection of the wastewater treatment plant. The inspection date identified in the letter was in error. Attached is a revised letter with the correct date. Please disregard the previous letter.

You may contact this writer at (330) 963-1251 or at [john.kwolek@epa.state.oh.us](mailto:john.kwolek@epa.state.oh.us) to discuss any questions you may have.

Respectfully,

John Kwolek  
District Engineer  
Division of Surface Water

JK/mt

cc: Joe Mansky, Mahoning County Department of Health