



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 2, 2007

RE: MAHONING COUNTY
GREEN TOWNSHIP
SERENITY HOUSE
NPDES PERMIT NO. 3PR00356

Mr. Gary M Hamilton
6131 W. Western Reserve Road
Canfield, OH 44406


Dear Mr. Hamilton:

On September 24, 2007, this writer inspected the wastewater treatment system for Serenity House located at 9182 U.S. Route 62 in Canfield. The inspection confirmed that Serenity House remains closed, and that the wastewater treatment system is not discharging wastewater at this time.

A review of the Monthly Operating Reports (MORs) for Serenity House shows that Serenity House failed to submit MORs for July and August 2007. Be advised that even though the system is inactive, you still must submit the Monthly Operating Reports. Failure to do so is a violation of the NPDES Permit and Ohio Revised Code 6111.07. The reports must be submitted each month to the Columbus address in Part III of the NPDES Permit. As previously discussed, use of the "AL" code in the upper left hand cell of the report indicates no discharge from the system for the entire month.

You may contact this office at (330) 963-1251 to discuss any question you may have.

Respectively,



John Kwolek
District Engineer
Division of Surface Water

JK/mt

cc: Joe Mansky, Mahoning Department of Health